

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1209:169 Page 1 of 1

CATEGORY: Fire Alarm Devices For The Hearing Impaired

LISTEE: System Sensor, 3825 Ohio Avenue, St. Charles IL 60174
Contact: Andrej Nikolic (630) 377-6674

DESIGN: Models RP1215ADA (15cd), RP2415ADA (15cd), RP121575ADA (15/75cd), RP241575ADA (15/75cd), RP2475ADA (75cd), and RP24110ADA (110cd) strobe lights. May followed by letter "B" denoting the color beige. The RP Series (Retro Plate) lights employ snap-latch tabs for mounting to the horn/strobe plate. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 10.5 - 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control unit. The strobe light may be mounted to listee's separately listed compatible audible devices. For **wall mount** and **indoor** use only.

10-16-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 8, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager